



Ensuring Spent Fuel Pool Safety

Michael Weber
Deputy Executive Director for Operations
U.S. Nuclear Regulatory Commission


American Nuclear Society Meeting
June 28, 2011

Insights from Fukushima

- Nuclear emergency at Fukushima-Daiichi
 - 3 nuclear reactors
 - 4 reactor spent fuel pools
 - 1 common spent fuel pool



U.S. Spent Fuel Pools



- Spent fuel rods stored in spent fuel pools (SFPs) under at least 20 feet of water
- Typically $\sim 1/4$ to $1/3$ of fuel in reactor replaced with fresh fuel every 18 to 24 months
- Spent fuel stored in pools minimum of 5 years

U.S. SFP Safety

- Spent Fuel Pools (SFP) originally designed for limited storage of spent fuel until removed off-site
- Safety of spent fuel in pools achieved primarily by maintaining water inventory, geometry, and soluble boron (PWRs)
- Drain down can lead to uncovered fuel, heat-up, and the release of radionuclides

Risk of Large Release

- SFP risk is low, due to the low frequency of events that could damage the thick reinforced pool walls
 - Frequency of fuel uncover; $6E-7$ to $2E-6$ /yr. – NUREG-1738
 - Consequences have been assessed to be large due to the potential for heatup of all the fuel in the pool
 - Heatup of the fuel in the pool can lead to “zirconium fire” initiation and propagation
 - Large inventory of Cs-137

SFP Safety and Security


- NRC extensively reexamined pool safety and security after 9-11 attacks
 - Vulnerability to attack
 - Significantly improved analysis of fuel coolability / heatup
 - Assessment of mitigation measures to improve coolability of fuel
 - Improved fuel configuration within the pool achieves substantially greater passive cooling capability by natural convection

SFP Safety and Security

- Additional analyses of a spray system for spent fuel pool cooling
- NRC required spray capability for each site to improve active cooling capability
- Licensees performed site-specific assessments; NRC inspected
- Coolability of fuel within pools has been enhanced by measures identified and assessed as part of post-9/11 research
- Conducting research to confirm understanding and validate analytical modeling

Zirconium Fire Investigations During SFP Loss of Coolant Accident (LOCA)

- Prototypic full length 9x9 BWR hardware
 - Single pool rack cell
 - Upper & lower tie plates with seven spacers
 - Water tubes and channel box
 - 74 electric heater rods with Zr-2 cladding (eight partial length)
 - 5000 W simulating a 100 day old assembly
- Measurements
 - Temp profiles: Axial and radial
 - Induced flow: Effect of ignition on flow
 - O₂ concentration: Determine depletion
 - Nature of fire: Initiation location & axial burn rate



Zirc Fire Investigations During SFP LOCA – Postmortem




Full Length
Single
Assembly
Ignition
Movie

Removing Fuel from Pools

- NRC has considered benefits of removal of fuel from the pool and returning to a low density racking type configuration
- There are competing factors in such a consideration
 - Storage in dry casks must be consistent with certificate
 - Discharging of fuel increases the risk of cask drops and worker doses
 - Removal of fuel will decrease the inventory of Cesium-137
 - Removal of fuel does not appreciably reduce decay heat (most of the decay heat is from recently discharged fuel)
 - Reduction in potential land contamination and economic impacts, if a large release occurred

Impact of Removing Assemblies

Reduction of pool thermal heat load



Comparative Consequence Study

- NRC is initiating an updated SFP study
- Estimate the change in accident consequences associated with removing older fuel from the SFP and placing it in dry storage
- Limited scope analysis (e.g., single SFP/operating cycle for low/high density racking)

Comparative Consequence Study for SFP

- Technical approach relies on realistic analysis using expedient but technically-defensible deterministic methods and assumptions.
- Elements of study include
 - Information gathering
 - Seismic and structural assessment
 - Accessibility, decay heat, and radionuclide inventory assessment
 - Accident progression (MELCOR) and offsite consequence analysis (MACCS2)
 - Emergency planning assessment

Conclusions

- No immediate safety concerns based on Fukushima nuclear emergency
- Confirmed the existing safety measures for SFPs
- Examining both the near-term and long-term reviews
- Spent fuel needs to be managed safely and securely

